



## Wellington North Power Inc.

290 Queen Street West, PO Box 359, Mount Forest, ON N0G 2L0  
 Phone: 519.323.1710 Fax: 519.323.2425

[www.wellingtonnorthpower.com](http://www.wellingtonnorthpower.com) E-mail: [customerservice@wellingtonnorthpower.com](mailto:customerservice@wellingtonnorthpower.com)

ESA # 7012854

## Approved Meterbase

### SINGLE PHASE

The following list of Meterbase Manufacturers and Models are examples that meet the requirements of Wellington North Power Inc. Other Manufacturers and Models may be allowed, however, they must first be reviewed and approved by Wellington North Power Inc. prior to installation.

All meterbases are to be 600V rated, ring-type and meet the latest CSA/ ESA Approvals and standards.

For multi-unit stacked apartment style meter units, please submit specifications to WNP for review and approval.

#### Single Phase, 3-wire, 4-jaw, Form 2S, 120/240V

\* Underground services must be a 200A “oversized” meterbase.

\* Specialty meterbases (transfer switch, breaker or load centre combination) are not listed below and will need to be reviewed and approved by WNP.

Service Type	Manufacturer	Model
200A Overhead/ Underground	Microelectric	BS2-TCVBC
	Hydel	EK Series
	Eaton	LM Series

#### Single Phase, 3-wire, 5-jaw, Form 3S, 120/240V, Transformer rated

\*must have 5<sup>th</sup> jaw located at the 9 o’clock position

\*where a meterbase comes prewired with an installed Current Transformer, the contractor is responsible to ensure that WNP receives the CT test card. Failure to provide this may result in the meterbase not being accepted

Service Type	Manufacturer	Model
400A Meter Socket	Microelectric	JS4AB-300/5
	Hydel	CT4-TSB3
	Eaton	TCC5-TH



## Wellington North Power Inc.

290 Queen Street West, PO Box 359, Mount Forest, ON N0G 2L0  
 Phone: 519.323.1710 Fax: 519.323.2425

[www.wellingtonnorthpower.com](http://www.wellingtonnorthpower.com) E-mail: [customerservice@wellingtonnorthpower.com](mailto:customerservice@wellingtonnorthpower.com)

ESA # 7012854

CM Service	Hydel	CTS405PW-TS
	Eaton	TSU5-H1C

### Single Phase, 3-wire, 4-jaw, Form 2S, 120/240V, multi-position

- \* All multi-position meterbases must have the blank compartment for line-side terminations.
- \* Customer/ Contractor to complete an Electric Service Meterbase/ billing Verification Form and submit prior to connection
- \* Meterbases are to be properly and permanently labelled for the unit that they feed.
- \* All meterbases that will not have a meter installed at the time of connection will need to have a proper meter plate installed and sealed by WNP.

Service Type	Manufacturer	Model
200A Main, 100A per position	Hydel	SDC Series
	Eaton	KN1 Series
200A Main, 200A per position	Microelectric	BDA2 Series
	Hydel	HC20 Series
	Eaton	K2 Series
400A Main, 200A per position	Microelectric	BS4 Series
	Hydel	HC40 Series
	Eaton	K4 Series