

NOTES:

- 1. Meterbase to be located on the same side of the house that the service enters the property.
- Meterbase to be installed outdoors in a location, which is and will remain unobstructed by fences, hedges, expansions, sunrooms, porches/ decks and any other impediments.
- 3. Meterbase and conduits must not be recessed/ enclosed in any walls.
- 4. See WNP "Approved Meterbase" document for further information.
- 5. Entire trench from wire coil to meterbase location to be left open for inspection.
- 5.1. Once wire has been inspected and approved, Contractor to install wire into duct to meterbase. Ensure that new duct is properly joined to the existing duct.
- 6. Backfill to be clean, free of debris/ rocks and be well-tamped.
- 7. On installations where WNP are installing the cable, Contractor to supply and install a pull rope of sufficient strength for WNP to pull in wire.



Drawn By:

Date

Scale:

B. Gilbert

04/27/2023

N.T.S.

Title:

Trench Detail - Secondary Underground Service

Drawing No:

Rev No:

UG-SEC-001

0